



k w a l i t e i t v o o r a l l e v e i l i g h e i d

DECLARATION OF PERFORMANCE

Nr. 1013

- | | |
|---|--|
| 1. Unique Product Identification: | ASD-10 |
| 2. Batch number / Production date: | See product packaging |
| 3. Intended use: | Fire protection |
| 4. Name and contact address of the manufacturer: | Fito Products BV
Molenvliet 22
3961 MV Wijk bij
Duurstede
The Netherlands |
| 5. Name and contact address of the authorized representative: | Not applicable |
| 6. System of assessment and verification of constancy of performance: | System 1 |
| 7. Harmonized standard: | asbl ANPI vzw 122 |

The notified product certification body shall issue the certificate of constancy of performance of the product on the basis of determination of the product type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product; initial inspection of the manufacturing plant and of factory production control; continuous surveillance, assessment and evaluation of factory production control. Under system 1 and issued:

1134-CPR-122

- | | |
|-----------------------------------|----------------|
| 8. European Technical assessment: | Not applicable |
|-----------------------------------|----------------|

Molenvliet 22 - 3961 MV Wijk bij Duurstede - The Netherlands - Tel.: +31 (0) 343 578920 - Fax: +31 (0) 343 573298

RABO Bank: 30.21.88.304 - IBAN: NL12RABO0302188304 - BIC: RABONL2U

KvK: Utrecht 30222114 - BTW: NL817479296B01 - E-mail: info@fito.nl - www.fito.nl

*Levering geschied uitsluitend volgens onze Algemene Leverings- en Betalingsvoorwaarden, welke zijn gedeponneerd bij de KvK te Utrecht.
Only Fito Products BV terms and conditions of sale shall apply. Our general conditions of sale will be sent to you on request.*





k w a l i t e i t v o o r a l l e v e i l i g h e i d

9. Declared performance:

Essential characteristics:	Performance:	Harmonised technical specification:
Nominal activation conditions/sensitivity, response delay (response time) and performance under fire conditions:	Passed	EN14604:2005/AC:2008
Operational reliability:	Passed	
Tolerance to supply voltage:	Passed	
Durability of operational reliability and response delay, temperature resistance:	Passed	
Durability of operational reliability, vibration resistance:	Passed	
Durability of operational reliability, humidity resistance:	Passed	
Durability of operational reliability, corrosion resistance:	Passed	
Durability of operational reliability, electrical stability:	Passed	

10. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer:

Wijk bij Duurstede 01-07-2013

O.A.J. Honders
DGA