



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



EU TYPE EXAMINATION CERTIFICATE – Design Type In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU	Certificate N° 23/IT/5031-0-REV 0
---	--

Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 I-27020 Torre d'Isola (Pavia) ITALY

Concerned Equipment: Stored Pressure Aluminum Water Based - Portable Fire Extinguishers & Related Cylinders

Type: Group SP-AL-WB

- a) **FS2-Y-P; WS2-YP; WS2-Y LI** (revisie A – 28/10/2022)
- b) **FS6-EVF-JM-JMF-JMZ-JMFZ-J-JF-LH-LHF-LHZ-LHFZ** (revisie A – 28/10/2022)
WS6-JMA-JMP-JM-JM LI- JMAZ-JMPZ-JMZ-JMZ LI-JA-JP-J-J LI-LHA-LHP-LH-LH LI- LHAZ-LHPZ-LHZ-LHZ LI
(revisie A – 28/10/2022)
- c) **FS9-EV-JM-JMF-JMZ-JMFZ-J-JF-LH-LHF-LHZ-LHFZ** (revisie A – 28/10/2022)
WS9-JMA-JMP-JM-JM LI- JMAZ-JMPZ-JMZ-JMZ LI-JA-JP-J-J LI-LHA-LHP-LH-LH LI- LHAZ-LHPZ-LHZ-LHZ LI
(revisie A – 28/10/2022)

Capacities: 2 - 6 – 9 l

Set pressure at 60°C: max. 13,98 bar (2l) - max. 17,48 bar (FS6-EVF & all 9 l) - max. 15,38 bar (all other 6 l)

Test pressure: 20 bar (2l) – 25 bar (FS6-EVF & all 9 l) - 22 bar (all other 6 l)

Service temperature range: 5°C/+60°C (J-JM-JMZ-LH-LHZ) ; 0°C/+60°C (all others)

Used Standard : EN3.7:2004 A1:2007 & EN3.8:2021

The manufacturer is allowed to affix the "CE" mark followed by the notified body identification n°, to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module D are fully complied with.

The approval is valid until 06/02/2033

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the pertinent EN3 standards in force and the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.

Approval Date : 06/02/2023	Name : Ir. B. NEVE	Position : General Manager
Notified body identification number : 0029	Signature 	
Notified body:	APRAGAZ VZW / ASBL	
Notified body reference :	P4434/000	